

04-13-2013 at 16:04

Site Check Report

Kyle Hart

Canadian Doormaster Electric Ltd.
#7 - 3051 Underhill Avenue
Burnaby, BC
V5A 3C2
P: 604-421-3603
F: 604-717-1091
www.canadiandoormaster.com

Technician's Email:
Technician's Phone #:
Supervisor's Email:
cc Email:

kyle@canadiandoormaster.com
kathy@canadiandoormaster.com
colleen@canadiandoormaster.com

Bill To:		Customer Information		Ship To:	
Sample 1234 Main St Nowhereville, BC		John Smith P: (604) 555-4321 F: (604) 555-5432 John.smith@sample.com		Sample 1234 Main St Nowhereville, BC	
John Smith P: (604) 555-4321 F: (604) 555-5432 John.smith@sample.com				John Smith P: (604) 555-4321 F: (604) 555-5432 John.smith@sample.com	

Opening Details: Construction: Steel - Welded Width: 19'11" (239") Height: 15'11" (191") Sideroom: 8" (8") Headroom: 30'0" (360")		Door Details: Cycle Life: 25,000 Finish: Painted White Insulated: Non-Insulated Make: Kinnear Model: 2400 Spring #1: 6" x .3437 x 51.0" RHW Stretched		Spring #2: 6" x .3437 x 51.0" LHW Stretched Spring #3: 6" x .3437 x 51.0" RHW Stretched Spring #4: 6" x .3437 x 51.0" LHW Stretched Serial #: 82653 Identifier: NORTH WEST DOOR 6	
Type: Steel Door Width: 20'2" (242") Height: 16'0" (192") Thickness: 2" (2") Lift Type: Full Vertical Lift Track Size: 3" Reverse Angle Mounted					

Type: Hoist - LH Wall Mounted		Motor Details: Model: OGHW Serial #: 64-0380		Power: 460V 3PH 1HP Date of Manufacturing: August 3 1980	
Manufacturer: Manaras Operating Mode: C2					

Control Details: Receiver: Liftmaster 312HM Transmitter: Liftmaster 890MAX Push Button Station: PBT-3		Safety Details: Door Edge: MillerEdge PS-20	

NOTES: Safety edge not working.

